

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. DLL/MID/2026/T-0318

Dated: 18/07/2026

It is certified that an inspection team headed by Dr. Hiren Samra

(Name of Officers with designation) from Public Health Department

PHED inspected the Holy Child Public School, Mangaldai

(Name & Address of the school) on 14/07/2026

date of inspection) and on the basis of Water Test Report (Attached) bearing no. DLL/MID/2026/T-0318

dated 14/07/2026 of Mangaldai (PHED Lab) certified that the

Holy Child Public School, Mangaldai

(Name of school) has safe drinking water facilities for the

students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 17/07/2029

Signature with Seal: [Signature]

Asstt. Executive Engineer (PHE)
Mangaldai Sub-Division

Name : Mangaldai

Designation :

Name & Address of the Office / Department : ...

.....

..

To

Holy Child Public School

Mangaldai

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

DISTRICT LEVEL LABORATORY (PHE) MANGALDAI

ADDRESS: O/O, THE EXECUTIVE ENGINEER(PHE), MANGALDAI DIVISION, DARRANG, ASSAM
email id: dllphemld@gmail.com ; Contact: 9365734383

TEST REPORT

ULR NO.:TC-144122600000 0318F

Issue no.: DLL/MLD/2026/ 0318

Dt. 18-07-2026

TEST REPORT NO.	: DLL/MLD/2026/ T- 0318	REF NO	: -
SAMPLE RECEIVED DATE	: 14-07-2026		
SAMPLE ID	: DLL / MLD / 01/ 14-07-2026		
REPORT ISSUED TO	: HOLY CHILD PUBLIC SCHOOL		
SAMPLE LOCATION	: HOLY CHILD PUBLIC SCHOOL		(PIN POINT LOCATION)
ADDRESS	: VILLAGE : 2-NO BEZPARA	BLOCK	: PACHIM MANGALDAI
	: HABITATION : 2-NO BEZPARA	P.O	: HOWLY MOHANPUR
	: G.P. : NAGARBAHI	DISTRICT	: DARRANG :: ASSAM; PIN: 784529
CUSTOMER NAME	: RAJENDRA DEY	CONTACT:	: 8822915969
SAMPLE SOURCE	: GROUND WATER (STW)	SAMPLE TYPE	: CLEAR WATER
SAMPLE QUANTITY	: 1000 ml	SAMPLE COLLECTED ON	: 14-07-2026
DATE OF ANALYSIS	: 14-07-2026	ANALYSIS COMPLETED ON	: 18-07-2026
SAMPLE CONDITION	: Good , at 4°C	ANALYSIS CONDITION	: Temp: 23.6°C ; RH: 63.2 %

RESULT

Sl.no.	Parameters	Protocol used	RESULT	IS:10500:2012(2nd Revision)		Unit
				Desirable Limit	Max. Permissible Limit (In absence of better source)	
1	Colour	IS : 3025 (Part 4)	2	5	15	HU
2	Odour	IS : 3025 (Part 6)	Agreeable	Agreeable	NR	-
3	Taste	IS : 3025 (Part 8)	Agreeable	Agreeable	NR	-
4	pH	IS : 3025 (Part 11)	6.89	6.5-8.5	NR	pH Unit
5	Turbidity	IS : 3025 (Part 10)	3.5	1	5	NTU
6	Total Iron (as Fe)	APHA-3500-Fe,B:2024	BDL	1	NR	mg/l
7	Fluoride (as F)	APHA-4500-F,D:2024	BDL	1	1.5	mg/l
8	Arsenic (as As)	IS : 3025 (Part 37)	BDL	0.01	NR	mg/l
9	Nitrate-Nitrogen (as NO ₃)	APHA-4500-NO ₃ ⁻ ,B:2024	BDL	45	NR	mg/l
10	Sulphate (as SO ₄)	IS : 3025 (Part 24/1)	5.358	200	400	mg/l
11	Total Alkalinity (as CaCO ₃)	IS : 3025 (Part 23)	40	200	600	mg/l
12	Chloride(as Cl)	IS : 3025 (Part 32)	19.852	250	1000	mg/l
13	Total Hardness (as CaCO ₃)	IS : 3025 (Part 21)	46	200	600	mg/l
14	Calcium (as Ca ²⁺)	IS : 3025 (Part 40)	10.421	75	200	mg/l
15	Magnesium (as Mg ²⁺)	APHA-3500-Mg,B:2024	4.86	30	100	mg/l
16	Total Dissolved Solids (TDS)	IS : 3025 (Part 16)	50	500	2000	mg/l

N.B:

Abbreviation: BDL: Below Detectable Limit, NR: No Relaxation, HU: Hazen Unit, NTU: Nephelometric Turbidity Unit

- The results given are related to the sample as received and tested in the laboratory. Reliability of sample lies with the sender.
- The test report cannot be regenerated/re-produced in whole or in part without written permission.
- The test report cannot be used for any publicity or any legal purpose.
- The test sample meant for chemical analysis will be disposed after 14 days from the date of receipt of water sample unless and until specially requested by the customer for retaining over a longer period.
- The laboratory is responsible for all the information given in the report.

Sample Analysed by
Asst Chemist

END OF TEST REPORT

Signatory Authority
Parag Nath
Quality Manager

DLL, Mangaldai